


Toronto Community
Housing Corporation
Strategic Procurement
931 Yonge Street, 6th Floor
Toronto, Ontario
M4W 2H2
Telephone Number (416) 981-4000
Fax Number (416) 981-4111
October 30, 2008



Dear Sir/Madam:

**Request for Proposal RFP 15/08
Supply and Installation of Solar Domestic Hot Water System
at 33 Coatsworth Crescent**

=====

ADDENDUM # 4

Q1: In the RFP 15/08, you require us to submit a computer based estimate of performance output using accepted NRCan practice. We are going to use Retscreen software. However, to run the model, it needs some inputs like miscellaneous losses, city water temperature, tc. To be fair to all contractors is it possible for TCH to set up certain values for all of these inputs so that all the energy output results will be based on the same assumptions.

A2: General Inputs / Assumptions for Computer Models:

Inlet water temperature:	Min 5 C	Max 17 C
Gas Costs	\$0.55 per m3	
Electricity Costs	\$0.12 per kWh	
Boiler Efficiency	80%	
Inflation Rate	2.5 %	
Hot Water Consumption	assume 227 litres/day/suite	(128 suites in building)

Other program inputs to be determined by system parameters.

This Addendum now forms part of this RFP and proponents are reminded that receipt of all Addenda must be acknowledged on item 3 (c) of the RFP Submission Form (Appendix A).

Yours truly,

Carroll C. Duff
Senior Purchasing Officer
Strategic Procurement
Toronto Community Housing

End of Addendum #4