

Toronto Community Housing Company
Strategic Procurement
931 Yonge Street, 6th Floor
Toronto, ON M4W 2H2
Tel: 416-981-4100
Fax: 416-981-4111



March 3, 2009

Dear Sir/Madam:

**RE: RFP 01/09 – SUPPLY AND INSTALLATION OF SOLAR DOMESTIC HOT
WATER SYSTEM AT 33 COATSWORTH CRESCENT**

ADDENDUM #5

QUESTION AND ANSWER for RFP 01/09

Addendum #5 consists of **two (2)** pages including this cover letter.

The closing time and date of 11:00:00 A.M., Local Time, Monday, March 16, 2009, remains the same.

This addendum now forms part of this Request for Proposal and proponents are reminded that receipt of all Addenda must be shown on the RFP Submission Form.

Yours truly,

Ruth M. Allder
Senior Purchasing Agent (Acting)

Cc: Xhavit Zaganjori
Renewable Energy Coordinator

ADDENDUM #5

QUESTION AND ANSWER

Q1: We have run through a preliminary design for the layout of the collectors on the roof. The challenge is where to place the big solar storage tank. In the attached drawing, we temporarily place the 20M3(20000L, 22000Kg) tank on the roof. Can you suggest a couple of alternative locations where the solar storage tank can be located, thanks.

A1: Thank you for your question regarding storage location. As long as the storage tanks meet mechanical and structural engineering approval, these can be located on the roof, or in the mezzanine area, or by taking advantage of the existing DHW storage (see previous addendum), as long as the proposed system does not have a negative impact on access or on normal DHW system functioning, and meets the other requirements as outlined in the RFP.

END OF ADDENDUM #5