
| | |
|------------------------|---|
| Addendum Number | 3 |
| Addendum Date of Issue | April 16, 2020 |
| RFP Number | RFP 20085 PP |
| RFP Description | Heating and Cooling System Retrofit at 11 Randolph Ave. |
| Page(s): | 1 |
| Attachment(s): | 0 |

This Addendum forms part of the above mentioned RFP document and is to be read, interpreted, and coordinated with all other parts. The following revisions supersede the information contained in the original RFP documents issued for the above-named project to the extent referenced and shall become part thereof.

The following information supplements and/or supersedes the RFP document issued on March 18, 2020.

1. QUESTIONS AND ANSWERS

Q1. Do I need to include BACnet on DHW and separately on Boilers? 1 BACnet can support up to 32 devices.

A1. Each boiler shall be equipped with BACnet card.

All other terms and conditions remain the same.

Amanda Abbott
Sourcing Manager, Strategic Procurement

[End of Addendum #3]
