

---

<b>Addendum Number</b>	5
Addendum Date of Issue	April 22, 2020
RFP Number	RFP 20085 PP
RFP Description	Heating and Cooling System Retrofit at 11 Randolph Ave.
Page(s):	1
Attachment(s):	0

---

This Addendum forms part of the above mentioned RFP document and is to be read, interpreted, and coordinated with all other parts. The following revisions supersede the information contained in the original RFP documents issued for the above-named project to the extent referenced and shall become part thereof.

The following information supplements and/or supersedes the RFP document issued on March 18, 2020.

#### **1. RFP TIMETABLE**

- a. **The Submission Deadline**, as stated in the RFP Timetable, has been changed to Thursday, April 30, 2020. The closing time remains the same at 2:00:00 p.m. Toronto time.

#### **2. QUESTIONS AND ANSWERS**

Q1. Multiple questions related to BAS BacNet card for Heating and DHW boilers.

A1. We will only accept separate BacNet converter for each boiler as was specified in the drawings.

All other terms and conditions remain the same.

Amanda Abbott  
Sourcing Manager, Strategic Procurement