



| | |
|------------------------|--|
| Addendum Number | 2 |
| Addendum Date of Issue | January 28, 2021 |
| RFP Number | 20316-PP |
| RFP Description | Construction-Common Area Accessibility Upgrades-140 Adanac Drive |
| Page(s): | 2 |
| Attachment(s): | 0 |

This Addendum forms part of the above mentioned RFP document and is to be read, interpreted, and coordinated with all other parts. The following revisions supplements and/or supersedes the information contained in the original RFP documents issued on December 29, 2020 for the above-named project to the extent referenced and shall become part thereof.

1. QUESTIONS AND ANSWERS (answers in bold)

1. Please provide specs for signage G1 and G2. Besides sizes, there are no other details provided.
12mm thick acrylic sheet with direct print letters.
2. Please provide spec for porcelain tile FF4. Thank you.
Exact spec to be confirmed. For pricing purposes assume similar to FF1.
3. What is the height of the floor to deck?
Refer to answer to Question 27 in Addendum 1.
4. Where is the spec. for tiles Ff4 & Wf4?
Exact spec to be confirmed. For pricing purposes assume similar to FF1 and WF1.
5. In workshop are we removing perimeter walls. If so what type of new walls to be applied, it is not shown.
Refer to folder RFP 20316-PP - Appendix B – Scope of Works, Drawings and DSA Report, file 20201218_140_Adanac_Arch_Struc_Elec_Mech and page A100. The note on drawing 02/A100 "Remove all interior metal lath and plaster walls and ceiling with wall finish materials. Expose the structural walls/cmu walls" only applies to the new Accessible Laundry Room area. Does not apply to the new workshop and storage area.
6. Is new ceramic in all rooms goes also to existing walls or no. This wall get painted or else.
Refer to folder RFP 20316-PP - Appendix B – Scope of Works, Drawings and DSA Report, file 20201218_140_Adanac_Arch_Struc_Elec_Mech, elevations on page A500 and finish schedule on page A002.

7. What type of hand dryer required in universal washroom.
Surface - Mounted ADA Dryer, Model# B-7128, by Bobrick

All other terms and conditions remain the same.

Joanne Bourne-James
Sourcing Manager, Strategic Procurement

[End of Addendum #2]