

Toronto Community Housing Corporation
 Strategic Procurement
 35 Carl Hall Rd. Unit 1
 Toronto, Ontario M3K 2B6



Addendum Number	8
Addendum Date of Issue	April 07, 2020
RFQ Number & Name	RFQ 20034 - Office Furniture Solution for TCHC Regional Hubs
Page(s):	2, excluding attachments
Attachment(s):	N/A

This Addendum forms part of the above mentioned RFQ document and is to be read, interpreted, and coordinated with all other parts. The following revisions supersede the information contained in the original RFQ documents issued for the above-named project to the extent referenced and shall become part thereof.

The following information supplements and/or supersedes the RFQ document issued on **February 26, 2020**.


ADDITIONAL PROPONENT QUESTIONS

As follows. Please note no additional Proponent questions will be entertained after this Addendum.

QUESTION	ANSWER
1. How many cables are required for each workstation?	Each workstation will be provided with 1 (one) CAT6 cable that will be used for phone and docking station. There will be two (2) monitors per desk so power is requested as six (6) per workstation. Refer to latest Addendum version of Appendix B – Scope of Work for additional information.
2. What category cable required (i.e. CAT6, CAT6A)?	CAT6
3. Do you require any patch cords for LAN Room End and Workstation End?	No. TCHC IT will provide all patch cords.
4. What are the working hours, regular or after hours?	Refer to latest Addendum version of Appendix B – Scope of Work
5. Are we required to carry a patch panel or assume existing?	Assume existing

All other terms and conditions remain the same.

Sincerely,

DocuSigned by:

F88D7D4C4F88453...

Rajesh Singh
Sourcing Manager