

---

<b>Addendum Number</b>	3
Addendum Date of Issue	April 11, 2022
RFQ Number	RFQ 22087
RFQ Description	Supply Insuite and Common Area LED Lighting at 246 and 252 Sackville St.
Page(s):	1
Attachment(s):	n/a

---

This Addendum forms part of the above mentioned RFQ document and is to be read, interpreted, and coordinated with all other parts. The following revisions supplements and/or supersedes the information contained in the original RFQ documents issued on March 17, 2022 for the above-named project to the extent referenced and shall become part thereof.

**1. QUESTIONS AND ANSWERS (answers in bold)**

**246 Sackville St.**

1. What do you mean by a wire chase inside the fixture?

**Form C – Pricing, item 10 for 246 Sackville St. and item 3 for 252 Sackville St. The wire chase is an empty cavity inside the fixture allowing for back entry of wires into fixture anywhere along the fixture.**

All other terms and conditions remain the same.

Amanda Abbott  
Sourcing Manager, Strategic Procurement

[End of Addendum #3]