



Addendum Number	1
Addendum Date of Issue	July 22, 2022
RFQ Number	22241
RFQ Description	Supply Electrical Material for In-Suite and Common Area LED Lighting at 200 Sherbourne St.
Page(s):	2
Attachment(s):	N/A

This Addendum forms part of the above mentioned RFQ document and is to be read, interpreted, and coordinated with all other parts. The following revisions supplements and/or supersedes the information contained in the original RFQ documents issued on July 08, 2022 for the above-named project to the extent referenced and shall become part thereof.

1. QUESTIONS AND ANSWERS (answers in bold)

1. For Item #1,2 - will you accept PMMA instead of Polycarbonate lens?

Yes, PMMA will be accepted instead of Polycarbonate lens.

2. For Item #1.2 - which same company are this specs from?

The specifications are form RENO Lighting, however alternative model which meet the minimum specifications may be accepted.

3. For Item #1 - will you accept 26W and 1820 Lumens?

No, refer to the minimum specifications.

4. For Item #2 - will you accept 16W and 1120 Lumens?

No, refer to the minimum specifications.

5. For Item #2 - will you accept a 12" size?

No, refer to the minimum specifications.

6. Item #1.2 - will you accept single ring instead of double rings?

No, refer to the minimum specifications.

7. Item #1.2 Does it matter what color the double metal rings are?

Metal colour, satin or brushed nickel – in this colour group

8. Will you accept the items that are pending Energy Star or DLC certificates for the Canada and USA markets?

No – must meet requirements at this time due to energy rebate application

9. Item#7, 8, 9, 10, What dimensions are required for the deep and shallow body vandal fixture.

Deep body defines the fixture as accepting conduit entry into side of fixture. Refer to image provided which is deep body.

Shallow body does not allow conduit entry into sides of fixture. Therefore the lens wraps directly around fixture to ceiling.

There are 3 manufactures (Vioneering, BJ Take and Pioneer) that supply these fixtures. Please contact the manufactures directly for their specification sheets which will provide the dimensions.

Measurements for deep body depth – 4.25” approximately

Measurements for deep body depth – 3.5” approximately

10. For item #7, 8, 9, Please define or let us know what size/height you mean for DEEP and SHALLOW

Deep body defines the fixture as accepting conduit entry into side of fixture. Refer to image provided which is deep body.

Shallow body does not allow conduit entry into sides of fixture. Therefore the lens wraps directly around fixture to ceiling.

There are 3 manufactures (Vioneering, BJ Take and Pioneer) that supply these fixtures. Please contact the manufactures directly for their specification sheets which will provide the dimensions.

Measurements for deep body depth – 4.25” approximately

Measurements for deep body depth – 3.5” approximately

2. CLARIFICATIONS

1. The timetable on the main document should read as RFQ 22241 – Supply Electrical Material for In-Suite and Common Area LED Lighting at 200 Sherbourne St.

All other terms and conditions remain the same.

Amanda Abbott
Sourcing Manager, Strategic Procurement

[End of Addendum #1]