
Addendum Number	2
Addendum Date of Issue	November 18, 2022
RFQ Number	22329
RFQ Description	Supply, Delivery and Commissioning Boiler at 1615 Dundas St East
Page(s):	1
Attachment(s):	n/a

This Addendum forms part of the above mentioned RFQ document and is to be read, interpreted, and coordinated with all other parts. The following revisions supplements and/or supersedes the information contained in the original RFQ documents issued on November 10, 2022 for the above-named project to the extent referenced and shall become part thereof.

1. QUESTIONS AND ANSWERS (answers in bold)

1. Can you please advise can next products be accepted equal for heating boilers, PK Storm ST1250 - 97% efficiency, 208/1/60

Patterson-Kelley shall be accepted as an equivalent manufacturer for the heating boilers (Item A). Note that the Proponent must still fill the Mandatory Criteria Table in Submission Form B whether they carry the base or alternative equipment, and further identify the requested items in the Alternate Equipment Table if they plan on carrying an alternate model.

2. Can you please advise can next products be accepted equal for DHW boilers, PK SCD650 - 94.1E eff, 120/1/60

Patterson-Kelley shall be accepted as an equivalent manufacturer for the domestic hot water boilers (Item B). Note that the Proponent must still fill the Mandatory Criteria Table in Submission Form B whether they carry the base or alternative equipment, and further identify the requested items in the Alternate Equipment Table if they plan on carrying an alternate model.

All other terms and conditions remain the same.

Amanda Abbott
Sourcing Manager, Strategic Procurement

[End of Addendum #2]