
Addendum Number	Three (3)
Addendum Date of Issue	October 22, 2018
RFP Number	RFP 18352
RFP Description	Supply and Install of Electric Sub-metering System at Various TCHC Locations
Page(s):	2
Attachment(s):	0

This Addendum forms part of the above mentioned RFP document and is to be read, interpreted, and coordinated with all other parts. The following revisions supersede the information contained in the original RFP documents issued for the above-named project to the extent referenced and shall become part thereof.

The following information supplements and/or supersedes the RFP document issued on **October 16, 2018**.

1. QUESTIONS AND ANSWERS

Q1. We would like to supply Triacta Powerhawk 6000 Series meters. This manufacturer has been producing equipment for 15 years. Please confirm these can be accepted as an approved equal.

A1. Accepted for multi-suite metering, but ensure that the data integrates with the EIMS database.

Q2. We would like to utilize QMC's web-based software, Meterconnex, as an approved equal to Intellimeter EMS. Please confirm this can be accepted as an equal (see attachments for details).

A2. Accepted as approved equal.

Q3. Many of the suite breakers are not identified. Please confirm the proponent should carry the costs of conducting breaker to suite verification and that they will be given access to suites to complete this process.

A3. The proponent should carry the cost – access to suites will be provided by TCHC.

Q4. What are the working hours for this project?

A4. 9 a.m. to 5 p.m. Monday thru Friday (other hours to be arranged and approved by TCHC).

Q5. How long can power be shut down on each riser? Just want to confirm it is 3 hours.

A5. Maximum 4 hours.

All other terms and conditions remain the same.

Bakhadir Salakhutdinov

Sourcing Manager, Strategic Procurement
Toronto Community Housing

[End of Addendum #3]