

Addendum Number	1
Addendum Date of Issue	June 12, 2019
RFP Number	19178
RFP Description	RFP 19178 - Heating System Retrofit and Cooling Upgrade at 384 Mt. Pleasant Road
Page(s):	2
Attachment(s):	0

This Addendum forms part of the above mentioned RFP document and is to be read, interpreted, and coordinated with all other parts. The following revisions supersede the information contained in the original RFP documents issued for the above-named project to the extent referenced and shall become part thereof.

The following information supplements and/or supersedes the RFP document issued on **May 24, 2019**.

A. QUESTIONS

1. Who is roofing contractor?

Answer:

The roof is currently not under warranty. Proponent shall utilize a contractor from TCHC approved roofing contractor roster RFVQ 16296. See list below.

ROOF CONSTRUCTION SERVICES - RFVQ 16296						
Effective 01/02/2017 Expires 01/01/2020 - Two possible one year extensions						
Roofing	12456	Cordeiro Roofing Ltd	Wayne	(416) 234-9901	(416) 234-9581	info@cordeiroroofing.com
Roofing	12594	Eileen Roofing Inc.	Rui Cabral (C: 416-888-8483)	(416) 762-1819	(416) 762-7013	eileen@eileenroofing.com
Roofing	10588	Nortex Roofing Ltd	Peter Difazio	(416) 236-6090	(416) 236-6091	info@nortexroofing.com
Roofing	32470	Proteck Roofing & Sheetmetal Inc	Marco	(416) 630-2300	(416) 630-2310	info@proteckroofing.com
Roofing	32429	Rooftops And Sheetmetal Corporation	Sophie Wu	(905) 270-2507		rooftops@sympatico.ca
Roofing	10294	Trinity Roofing Ltd.	Robin Singh	(416) 630-9213	(416) 630-1722	trinityroofing@bellnet.ca;info@trinitycanada.com;robin@trinitycanada.com
Roofing	33475	Triumph Roofing & Sheet Metal Inc.	Vanessa Spagnuolo (ext 235)	(416) 534-8877	(416) 534-8863	vspagnuolo@triumphinc.ca;info@triumphinc.ca

2. Who is base BAS building contractor? Is it required to tie-in new system to existing one?

Answer:

The existing BAS is open to any contractors certified under the Niagara AX platform.

3. Drawing m-1, general note 1. "Prior to demolition asbestos to be removed by Licence asbestos contractor, if any." If this is by the Contractor, please forward an Asbestos Survey.

Answer:

There is no Asbestos Survey available.

All other terms and conditions remain the same.

Shams Umarov
Sourcing Manager

[End of Addendum #1]