



Addendum Number	1
Addendum Date of Issue	July 07, 2021
RFQ Number	RFQ 21156-PP
RFQ Description	Equipment Purchase and Delivery at 55 The Esplanade Ave.
Page(s):	1
Attachment(s):	n/a

This Addendum forms part of the above mentioned RFQ document and is to be read, interpreted, and coordinated with all other parts. The following revisions supplements and/or supersedes the information contained in the original RFQ documents issued on June 21, 2021 for the above-named project to the extent referenced and shall become part thereof.

1. QUESTIONS AND ANSWERS (answers in bold)

Q1: Are noncondensing boilers and water heaters acceptable? BTU output will be same or better than basis of design

A1: All new boilers must be condensing boilers based on the schedule.

Q2: The specification requests a 1050 which is 1.050 million BTU input. Most boiler manufacturers have a one million BTU input DHW boiler. Is a one million BTU boiler acceptable? I believe the sizing of the DHW system should be able to accept a 5% reduction in BTU on the system without any issues.

Q2: The minimum acceptable output is 1,000,000 BTU.

Q3: The heating boiler spec is 1600K BTU input heating boilers. In the previous discussion, 1500K input boilers were fine. Please confirm. Thank you

A3: 1,500,000 BTU is acceptable.

All other terms and conditions remain the same.

Amanda Abbott
Sourcing Manager, Strategic Procurement

[End of Addendum #1]